

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

### Monitoring Requirements Not Met

#### Town of Pe Ell Water System (ID# 66750) – Lewis County

Our water system has violated surface water treatment monitoring requirements. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

*We are required to monitor your drinking water for specific parameters on a regular basis. Results of regular monitoring are an indicator of whether our drinking water meets health standards. During the month of March 2021, we did not complete all monitoring necessary to determine if effective disinfection occurred.*

**What should I do?** There is nothing you need to do at this time.

The table below lists the parameter(s) we did not properly test for, how often we are supposed to sample for this parameter and how many samples we are supposed to take, how many samples we took and when samples should have been taken.

Parameter	Required sampling frequency	Number of samples taken	When all samples should have been taken
Chlorine Residual for Inactivation Ratios	Each day filtered water is produced.	None	Each day filtered water is produced.

**What happened? What is being done?** *[We have implemented that the Monthly Monitoring Reports are completely filled out and all calculations are done daily to ensure all Chlorine residual, Contact Time and Inactivation Times meet or exceed the WA DOH Standards the reports will be double checked by another operator.]*

For more information, please contact Brandon Salice at 360-324-2018 (Mobile Cell)

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*